



## OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of  
NSF/ANSI/CAN 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on August 7, 2026.

**ITW ProBrands**  
**4647 Hugh Howell Rd.**  
**Tucker, GA 30084**  
**800-241-8334**  
**678-272-4528**

Facility: # 1 USA

### Joining and Sealing Materials

| Trade Name                                     | Size | Water<br>Contact<br>Temp | Water<br>Contact<br>Material |
|------------------------------------------------|------|--------------------------|------------------------------|
| Sealants <sup>[1]</sup>                        |      |                          |                              |
| LPS® Strong Steel Stick™ Rene<br>wal Composite | [2]  | C. HOT                   | EPOXY                        |

[1] Mix ratio of Part A:Part B is 1:1

[2] The exposed surface area of sealant in a tank shall not exceed 0.60 sq. cm/L or 0.095 sq.  
in./L

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

1 of 1